

Applicable UI Charge in force w. e. f. 01 / 04 / 2009

### UI Rates

#### Average frequency of Time Block ( Hz. )

BELOW	NOT BELOW	PAISA / KWH
.....	50.3	0
50.30	50.28	12
50.28	50.26	24
50.26	50.24	36
50.24	50.22	48
50.22	50.20	60
50.20	50.18	72
50.18	50.16	84
50.16	50.14	96
50.14	50.12	108
50.12	50.10	120
50.10	50.08	132
50.08	50.06	144
50.06	50.04	156
50.04	50.02	168
50.02	50.00	180
50.00	49.98	192
49.98	49.96	204
49.96	49.94	216
49.94	49.92	228
49.92	49.90	240
49.90	49.88	252
49.88	49.86	264
49.86	49.84	276
49.84	49.82	288
49.82	49.80	300
49.80	49.78	312
49.78	49.76	324

BELOW	NOT BELOW	PAISA / KWH
49.76	49.74	336
49.74	49.72	348
49.72	49.70	360
49.70	49.68	372
49.68	49.66	384
49.66	49.64	396
49.64	49.62	408
49.62	49.60	420
49.60	49.58	432
49.58	49.56	444
49.56	49.54	456
49.54	49.52	468
49.52	49.50	480
49.50	49.48	497
49.48	49.46	514
49.46	49.44	531
49.44	49.42	548
49.42	49.40	565
49.40	49.38	582
49.38	49.36	599
49.36	49.34	616
49.34	49.32	633
49.32	49.30	650
49.30	49.28	667
49.28	49.26	684
49.26	49.24	701
49.24	49.22	718
49.22	49.20	735

Each 0.02 Hz step is equivalent to 12 . 0 paise / KWh in the 50 . 3 -- 49 . 5 Hz frequency range and to 17 . 0 paise / KWh in the 49 . 5 -- 49 . 2 Hz frequency range